

**AMBLER WATER SYSTEM PFAS SAMPLE RESULTS
2026 QUARTER 1 SAMPLING**

Well No. or Location	PFOA Average of Past Results (ppt)	PFOS Average of Past Results (ppt)	PFOA* 2026 Quarter 1 (ppt)	PFOS* 2026 Quarter 1 (ppt)	PFOA* 2026 Average (ppt)	PFOS* 2026 Average (ppt)
2	11.7	9.2	11.4	8.7	11.4	8.7
4	10.2	9.5	9.9	8.6	9.9	8.6
6	9.1	8.9	9.3	8.9	9.3	8.9
7	8.8	8.0	9.0	6.7	9.0	6.7
8	2.3	6.7	**	**	**	**
9	11.4	9.6	10.7	8.7	10.7	8.7
11	9.9	8.0	9.5	7.0	9.5	7.0
12	7.1	5.9	7.4	5.5	7.4	5.5
14	7.0	6.8	6.6	6.2	6.6	6.2
Whitemarsh WTP Raw	7.2	6.3	**	**	-	-
Whitemarsh WTP Treated***	2.7	1.4	ND	ND	ND	ND
Storage Tanks						
Loch Alsh Tank	11.9	8.9	10.0	7.7	-	-
Broad Axe Tank	7.9	6.1	4.9	2.7	-	-
Houston Road Tank	8.8	7.4	7.5	6.2	-	-

Notes:

ppt = parts per trillion

** = Not Sampled

ND = Not Detected

- = PFAS MCL Rule doesn't apply

Average of Past Results is the average of samples collected since 2016.

All 2026 Quarter 1 samples were collected on March 06, 2026, except the Whitemarsh Treated, which was sampled on April 8, 2026. All samples were analyzed by Regional Water Authority Lab Services - New Haven, CT

*PA DEP adopted "The Safe Drinking Water PFAS MCL Rule" in January 2023. The rule establishes an MCL of 14 ppt for PFOA and 18 ppt for PFOS and an MCLG of 8 ppt for PFOA and 14 ppt for PFOS. All sources are testing below the PADEP MCL for this quarter. Monitoring requirements under this rule began January 1, 2024. US EPA adopted the "Final PFAS National Primary Drinking Water Regulation" in April 2024. Under the regulation, initial monitoring must be complete by 2027 and compliance by 2029. The regulation establishes: an MCL of 4 ppt for PFOA and PFOS; an MCL of 10 ppt for PFNA, PFHxS, and HFPO-DA (GenX chemicals); a Hazard Index of 1 for PFNA, PFHxS, HFPO-DA, and PFBS. In May 2026 EPA proposed an extension of the deadline for compliance with PFOA And PFOS MCLs to 2031, and rescinding of the MCLs for PFHxS, PFNA, HFPO-DA and the Hazard Index.

***New carbon installed at Whitemarsh in March 2026.