

**AMBLER WATER SYSTEM PFAS SAMPLE RESULTS
JANUARY 2022 SAMPLING**

Well No. or Location	PFOA Average of Past Results (ppt)	PFOS Average of Past Results (ppt)	PFOA* January 2022 (ppt)	PFOS* January 2022 (ppt)
2	12.4	9.7	13.0	10.0
4	10.7	10.2	11.0	9.9
6	9.7	9.1	9.4	9.4
7	9.1	8.6	10.0	8.7
8	2.4	6.7	2.2	8.5
9	11.0	9.4	13.0	11.0
11	9.6	8.1	11.0	8.6
12	7.3	6.3	7.2	5.9
14	7.4	6.9	6.8	6.9
Whitemarsh WTP Raw	7.5	6.6	**	**
Whitemarsh WTP Treated	7.7	5.5	9.2	6.7
Storage Tanks				
Loch Alsh Tank	12.5	9.2	12.0	9.3
Broad Axe Tank	8.8	6.2	9.8	6.7
Houston Road Tank	9.2	8.1	8.3	6.4

Notes:

ppt = parts per trillion

** = Not Sampled

Average of Past Results is the average of samples collected in 2018, 2019, 2020, and 2021.

January 2022 samples were collected on January 27, 2022 and analyzed by Eurofins Philadelphia - Horsham, PA

*PA DEP adopted a proposed rule - "The Safe Drinking Water PFAS MCL Rule" - in November 2021. The rule proposes an MCL of 14 ppt for PFOA and 18 ppt for PFOS. While all sources are currently testing below the proposed levels, several are near the proposed MCL for PFOA. The proposed rule is subject to a public comment period that closes April 27, 2022. Following public comment, the proposed rule will be reviewed further and potentially revised before a final rule is considered and authorized.