AMBLER WATER SYSTEM PFAS SAMPLE RESULTS OCTOBER 2022 SAMPLING

	PFOA	PFOS	PFOA*	PFOS*
Well No. or Location	Average of Past Results	Average of Past Results	October 2022	October 2022
	(ppt)	(ppt)	(ppt)	(ppt)
2	12.5	9.6	11.0	8.9
4	10.8	10.1	10.0	9.3
6	9.6	9.1	9.4	8.1
7	9.4	8.4	8.7	6.7
8	2.3	6.8	**	**
9	11.4	9.6	12.0	9.2
11	10.1	8.2	**	**
12	7.3	6.2	7.1	5.8
14	7.4	6.9	5.9	5.8
Whitemarsh WTP Raw	7.8	6.3	7.9	5.9
Whitemarsh WTP Treated	8.0	5.7	ND	ND
Storage Tanks				
Loch Alsh Tank	12.5	9.2	11.0	8.6
Broad Axe Tank	9.6	6.9	ND	ND
Houston Road Tank	8.8	7.6	8.5	7.1

Notes:

ppt = parts per trillion

Average of Past Results is the average of samples collected since 2016.

October 2022 samples were collected on October 31, 2022 and analyzed by Eurofins Environment Testing Philadelphia - Horsham, PA

*PA DEP adopted a proposed rule - "The Safe Drinking Water PFAS MCL Rule" - in November 2021. The rule proposes an MCL of 14 ppt for PFOA and 18 ppt for PFOS. While all sources are currently testing below the proposed levels, several are near the proposed MCL for PFOA. Following public hearings and public comment, in October and November 2022, the PA Environmental Quality Board (EQB) and the Independent Regulatory Review Commission (IRRC) approved the regulation. The PA PFAS rule is expected to be finalized in 2023, which will include a schedule of effective dates for various components of the rule.

^{** =} Not Sampled