

**AMBLER WATER SYSTEM PFAS SAMPLE RESULTS  
JULY 2021 SAMPLING**

<b>Well No. or Location</b>	<b>PFOA+PFOS Average of 2018-2020 Results (ppt)</b>	<b>PFOA+PFOS April 2021 (ppt)</b>	<b>PFOA+PFOS July 2021 (ppt)</b>	<b>% of 70 ppt EPA Health Advisory Average of 2021 PFOA+PFOS</b>
2	20.7	25.0	17.7	31%
4	20.7	25.0	19.3	32%
6	14.9	24.0	15.1	28%
7	14.1	23.0	14.1	27%
8	8.2	9.0	9.3	13%
9	19.2	26.0	18.0	31%
11	16.7	23.0	15.6	28%
12	13.9	15.6	12.3	20%
14	13.9	18.9	11.6	22%
Whitemarsh WTP Raw	14.0	**	**	**
Whitemarsh WTP Treated	7.4	16.0	14.2	22%
<b>Storage Tanks</b>				
Loch Alsh Tank	20.3	23.9	16.7	29%
Broad Axe Tank	15.0	17.0	13.9	22%
Houston Road Tank	14.8	28.0	15.5	31%

Notes:

ppt = parts per trillion

\*\* = Not Sampled

Average of Past Results is the average of samples collected in 2018, 2019, and 2020.

April 2021 samples were collected on April 5, 2021 and analyzed by Eurofins QC, LLC - Horsham, PA

July 2021 samples were collected on July 9, 2021 and analyzed by Eurofins QC, LLC - Horsham, PA