

**AMBLER WATER SYSTEM PFAS SAMPLE RESULTS  
JULY 2022 SAMPLING**

Well No. or Location	PFOA Average of Past Results (ppt)	PFOS Average of Past Results (ppt)	PFOA* July 2022 (ppt)	PFOS* July 2022 (ppt)
2	12.4	9.7	13.0	8.5
4	10.7	10.1	12.0	9.6
6	9.7	9.1	9.0	9.4
7	9.3	8.4	9.8	8.1
8	2.3	6.8	**	**
9	11.4	9.6	**	**
11	10.1	8.3	9.8	7.0
12	7.2	6.2	7.9	6.1
14	7.4	7.0	6.9	5.7
Whitemarsh WTP Raw	7.6	6.5	8.3	5.1
Whitemarsh WTP Treated	8.0	5.7	**	**
<b>Storage Tanks</b>				
Loch Alsh Tank	12.4	9.2	13.0	9.2
Broad Axe Tank	9.3	6.6	12.0	8.8
Houston Road Tank	9.0	7.8	7.0	5.4

Notes:

ppt = parts per trillion

\*\* = Not Sampled

Average of Past Results is the average of samples collected in 2018, 2019, 2020, 2021, and January and April 2022.

July 2022 samples were collected on July 27, 2022 and analyzed by Eurofins Environment Testing Philadelphia - Horsham, PA

\*PA DEP adopted a proposed rule - "The Safe Drinking Water PFAS MCL Rule" - in November 2021. The rule proposes an MCL of 14 ppt for PFOA and 18 ppt for PFOS. While all sources are currently testing below the proposed levels, several are near the proposed MCL for PFOA. The proposed rule was subject to a public comment period that closed April 27, 2022. Following public comment, the proposed rule will be reviewed further and potentially revised before a final rule is considered and authorized.